



Compliance Statement

No. 2017-1009

Screened Permanent Link, Class E_A

Company

SOhome AS
Sandviksboder 77C
5035 Bergen
Norway

Permanent Link Identification (2 connector model)

Horizontal cable:

BC-10-021 Bergen Cabling DNV Maritime LAN S/FTP Cat.6A cable

Connecting hardware:

Keystone jack BC-11-004
Patch Panel BC-13-201 / BC-13-203

Generic cabling standards - Class E_A Permanent Link requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
 - EN 50173-1:2011
 - EN 50173-2:2007, including amendment A1:2010
 - ANSI/TIA-568-C.2:2009
- including all permanent link alien crosstalk parameters (PS ANEXT and PS AACR-F)

Technical report

DELTA-T735702-01, DANAK-19/18647

EC Cabling product ID

5881

CS valid until

1 April 2019

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 7 December 2017

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

DELTA – a part of FORCE Technology

Venlighedsvej 4 Tel. +45 72 19 40 00
2970 Hørsholm Fax +45 72 19 40 01
Denmark www.madebydelta.com/cable

