FORCE Technology

Attestation of Conformity

No. 2026-1606

Cables for use in construction works
Reaction to fire class D_{ca}

Company
Sohome AS
Grimstadvegen 93
5252 Søreidgrend
Norway

Product description
Copper communication cable, S/FTP, 22-23AWG, OD: 7.6-8.0mm, Cable parameter (χ): 49-62

Product identification
BC-I0-00I - BC Maritime cat.7 BC-IC001-2K- BC Maritime cat.7 - 2000 drum BC-I0.02S - BC Maritime cat.6A Stranded

Reaction to fire standards
- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015, A11:2016, and A12:2020
- EN 50399:2022
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018 including amendment A1:2022

Reaction to fire classification
Class D_{ca}-s2,d1,a1

Technical report
12631204-02, DANAK-19/26324

EC Cabling product ID
9200

This product has undergone a one-time test performed by Force Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 8 October 2026

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager

Force Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com